Confirmation

LEED

On 17 September 2012, Eurofins Product Testing A/S received a sample of ceiling board with the product name:

OWAConstruct

supplied by

Odenwald Faserplattenwerk GmbH

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000 and CDPH testing standards (See test report no. G17286D).

The test results of the tested product indicate that the product qualifies for LEED v4 and LEED 2009 specifications on VOC emissions by complying with:

VOC emissions specifications in LEED EQ credit "Low-emitting products":

- the requirements of CDPH-IAQ (California Department of Public Health, Feb 2010); and a TVOC below 0.5 mg/m³ in both office and class room.

31 October 2016

Maria Pelle
Chemist

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.