Confirmation

LEED v4.1

On 2 September 2020, Eurofins Product Testing A/S received a sample of a suspended ceiling panel with the product name:

OWAcoustic Premium

supplied by

OWA GmbH

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000, EN 16516, CDPH 01350 testing standards in the latest versions (See test report no. 392-2020-00376101_H_EN).

The test results of the tested sample indicate that the product qualifies for LEED v4.1 BETA (July 2019) specifications on VOC emissions by complying with:

VOC emissions specifications in LEED EQ credit "Low-emitting products":

- The requirements of Option 1 of LEED v4.1 BETA (July 2019): CDPH-IAQ (California Department of Public Health (CDPH) Standard Method v1.2-2017 (worst case relative to v1.0-2010)); and a TVOC below 0.5 mg/m³ in both office and class room.

15 October 2020

Pernille Krintel
Analytical Service Manager

Rasmus Stengaard Christensen
Analytical Service Manager, MSc in Chemistry

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.